



Elitis sa
Rue Jean Rodier 2
FR-31400 Toulouse
France

our message - reference

-

our reference

JW/4276

Gent

2026-03-12

Certification report 25/4276

1. Description of the product:

Product type	decorative wall covering metal vinyl on non-woven
Total mass	430 g/m ²
Thickness	< 1 mm

2. Test results:

EN ISO 11925-2 (exposure=30s)	EN 13823
----------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 70 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB

addressee	our reference	Gent	page
Elitis	JW/4276	2026-03-12	2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows according EN 13501-1:2018:

B – s2, d0

field of application: adhered with 200 g/m² vinyl adhesive on end-use substrates having a density of 1350 kg/m³ or higher and classified A2-s1,d0 or A1.

The evaluation of this property is based on evaluation scheme specified in EN 13501-1:2019: Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests.

Products fall under system 3 of assessment and verification of constancy of performance like declared by the manufacturer.

Related commercial names to this product group	FORMENTERA (VP 716 – VP 718 – VP 719) KINTSUGI (VP 1005 – VP 1006 – VP 1007 – VP 1022) LANZAROTE (VP 1029) OPENING (VP 724 – VP 726) RAFFIA & MADAGASCAR (VP 602) SOIE CHANGEANTE (VP 935) VIBRATIONS (VP 935 – VP 948 – VP 949 – VP 950 – VP 951 – VP 952 – VP 870 – VP 602 – VP 426) SAUVAGES (VP 971)
The obtained classification is based on the next test reports	AITEX: 2022AN6487 dd 26-07-2022
Validity of the certificate	25-07-2027

Jo Wynendaele, PhD

Consultant Floor and Wall Coverings

